

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT
For
FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)



I. FACILITY INFORMATION:

Business Name: Lowe's Home Centers, LLC
 Facility Name: Lowe's of S.W. Tucson #1791
 Source Location: 1800 W Valencia Rd, Tucson, AZ 85705

II. AUTHORIZED EQUIPMENT:

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

§ 6A of the Permit – Non-NSPS/Non-NESHAP ICE (Emergency Designated Engines):

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Limitation ¹	Allowable Fuels
359-001	Generator	Kohler	0773984	550 hp	10/01/2003	1/1/2004	100 hours	Diesel

¹ The run hours are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies. Permittee may also demonstrate compliance with the operational limitation by limiting the amount of fuel fired in the unit.

Rupesh Patel, Air Program Manager, PDEQ

Permit Number: #359	
Issued Date:	March 31, 2022
Effective Date:	March 31, 2022
Expiration Date:	March 30, 2027